Optical LLIS



Liquid Level Switches

Intrinsically safe for hazardous areas



Pin	Designation	Cable Pinout	Cable colour
1	+ Vs	1	Brown
2	NC	2	White
3	0 V	3	Blue
4	NC	4	Black



Do not exceed maximum ratings and ensure switch(es) is operated in accordance with requirements. Carefully follow all wiring instructions, as incorrect wiring may cause permanent damage to the device, and only apply power to the switch after all connections have been made.

PST recommends using alcohol-based cleaning agents. Do NOT use chlorinated solvents such as trichloroethane, as these are likely to attack the sensor material.

INFORMATION

As customer applications are outside of PST control, the information provided is given without legal responsibility. Customers should test under their own conditions to ensure the equipment is suitable for the intended application(s).

We adopt a continuous development program which sometimes necessitates specification changes without notice.

For technical assistance or enquiries about other options, please contact:

oxygen@processsensing.com.

Address: 5 Hagmill Crescent, Shawhead Industrial Estate, Coatbridge, UK, ML5 4NS Phone: +44 (0)1236 459 020 ©2023 Process Sensing Technologies